



## **Consumer Confidence Report 2021**

**City of Greenbrier Water Department  
790 West College St, Greenbrier, TN 37073  
PWSID TN0000271**

### **Mission Statement**

The City of Greenbrier proudly presents our 2021 Annual Water Quality Report covering all testing performed between January 1 and December 31, 2020. Over the years, the city has been dedicated to providing drinking water that meets all state and federal standards. We continually strive to adopt new methods for delivering the best quality drinking water to our residents. As new challenges to drinking water safety emerge, the City of Greenbrier remains vigilant in meeting the goals of source water protection, water conservation, and community education, while continuing to serve the needs of all of our water users. Please remember we are always available should you ever have any questions or concerns about your water.

For more information about this report, or for any questions relating to your drinking water, please call **Jason Harrington** at **615-643-4531**.

### **Where Does Our Water Come from?**

**Greenbrier Water System** purchases all of its water from the **City of Springfield Water System**. **The City of Springfield obtains its water from the Red River**. The City of Springfield in conjunction with the City of Greenbrier work closely together to ensure the Source Water Protection Plan and to do routine testing to ensure the quality of the water. The Source Water Assessment for Springfield Water System is available by contacting Bryan Suter at (615) 696-2586.

### **How can I get involved?**

The City of Greenbrier Board of Mayor and Aldermen meet on the first Monday night of each month at 7:00 P.M. at City Hall located at 790 West College Street. Please feel free to participate in these meetings.

### **Benefits of Chlorination**

Disinfection, a chemical process used to control disease-causing microorganisms by killing or inactivating them, is unquestionably the most important step in drinking water treatment. By far, the most common method of disinfection in North America is chlorination.

Before communities began routinely treating drinking water with chlorine (starting with Chicago and Jersey City in 1908), cholera, typhoid fever, dysentery, and hepatitis A, killed thousands of U.S. residents annually. Drinking water chlorination and filtration have helped to virtually eliminate these diseases in the U.S. Significant strides in public health are directly linked to the adoption of drinking water



## Consumer Confidence Report 2021

chlorination. In fact, the filtration of drinking water plus the use of chlorine is probably the most significant public health advancement in human history.

### How chlorination works:

Potent Germicide Reduction in the level of many disease-causing microorganisms in drinking water to almost immeasurable levels.

Taste and Odor Reduction of many disagreeable tasted and odors like foul-smelling algae secretions, sulfides, and odors from decaying vegetation.

Biological Growth Elimination of slime bacteria, molds, and algae that commonly grow in water supply reservoirs, on the walls of water mains, and in storage tanks.

Chemical Removal of hydrogen sulfide (which has a rotten egg odor), ammonia, and other nitrogenous compounds that have unpleasant tastes and hinder disinfection. It also helps to remove iron and manganese from raw water.

### Substances That Could Be in Your Water

In order to ensure that tap water is safe to drink, U.S. EPA and the Tennessee Department of Environment and Conservation (TDEC) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. U.S. Food and Drug Administration regulations establish limits for contaminants in bottled water and must provide the same protection for public health. ***Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of these contaminants does not necessarily indicate the water poses a health risk. More information about contaminants and potential health effects can be obtain by calling the EPA Safe Drinking Water Hotline at 800-426-4791.***

The sources of drinking water (both tap water and bottled water) include rivers, lakes, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals, in some cases radioactive material, and substances resulting from the presences of animals or human activity. Substances that may be present in source water include:

**Microbial Contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, or wildlife.

**Inorganic Contaminants**, such as salts and metals, which can be naturally occurring or may result from urban stormwater runoff, industrial or domestic wastewater discharges, oil, and gas production, mining, or farming.



## Consumer Confidence Report 2021

**Pesticides and Herbicides**, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential users.

**Organic Chemical Contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial process and petroleum production, and may also from gas stations, urban runoff, and septic systems.

**Radioactive Contaminants**, which can be naturally occurring or may be the result of oil and gas production and mining activities.

For more information about contaminants and potential health effects, call the U.S. EPA's Safe Drinking Water Hotline at (800) 426-4791.

### Important Health Information

**Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six (6) months of age.** High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, you should ask for advice from your health care provider.

*Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplant, people with HIV/AIDS or other immune system disorders, some elderly, and infants may particularly at risk from infections. These people should seek advice about drinking water from their health care providers. The U.S. EPA/CDC (Centers for Disease Control and Prevention) guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline at (800) 426-4791 or <http://water.epa.gov/drink/hotline>.*

### Lead in Home Plumbing

*If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Greenbrier Water System is responsible for providing high-quality drinking water, but we cannot control the variety of materials used in in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to two minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in your drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at (800) 426-4791) or at [www.epa.gov/safewater/lead](http://www.epa.gov/safewater/lead).*

### Test Results



## Consumer Confidence Report 2021

Our water is monitored for many different kinds of contaminants on a very strict sampling schedule. And, the water we deliver must meet specific health standards. Here, we only show those substances that were detected in our water (a complete list of all the analytical results is available upon request). Remember that detecting a substance does not mean the water is unsafe to drink; our goal is to keep all detects below the respective maximum allowed levels.

The State recommends monitoring for certain substances less than once per year because the concentrations of these substances do not change frequently. In these cases, the most recent sample data are included, along with the year in which the sample was taken.

The Springfield and Greenbrier Water Departments participated in the 4<sup>th</sup> stage of the U.S. EPA's Unregulated Contaminant Monitoring Rule (UCMR4) program by performing additional tests on their drinking water. UDMR4 sampling benefits the environment and public health by providing the U.S. EPA with data on the occurrence of contaminants suspected to be in drinking water, in order to determine if

U.S. EPA needs to introduce new regulatory standard to improve drinking water quality. Unregulated Contaminants Monitoring Rule, please call the Safe Drinking Water Hotline at 1-800-426-4791.

### Water Quality Data Table

**In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the number of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one-year-old.**

**In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.**



## Consumer Confidence Report 2021

Regulated Substances							
City of Springfield/City of Greenbrier Water Department							
Substance (Unit of Measure)	Year Sampled	MCL [MRDL]	MCLG [MR DLG]	Amount Detected	Range Low- High	Violation	Typical Source
Atrazine (ppb)	2020	3	3	1.8	ND-1.8	No	Runoff from herbicide used on row crops
Chlorine (ppm)	2020	[4]	[4]	3.0	1.1-3.1	No	Water additive used to control microbes
Fluoride (ppm)	2020	4	4	0.62	0.26-0.90	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Haloacetic Acids [HAA] Stage 2 (ppb)	2020	60	N/A	55	18-55	No	By-product of drinking water disinfection
Nitrate (ppm)	2020	10	10	5.7	2.9-5.7	No	Runoff from fertilizer use/ Leaching from septic tanks, sewage; erosion of natural deposits
TTHMs [Total Trihalomethanes] – Stage 2 (ppb)	2020	80	N/A	42	15-91	No	By-product of drinking water disinfection
Total Coliform Bacteria (% positive samples)	2020	TT	N/A	0	N/A	No	Naturally present in the environment
Total Organic Carbon <sup>1</sup> (% removal)	2020	TT	N/A	100	29-100	No	Naturally present in the environment

Turbidity <sup>2</sup> (NTU)	2020	TT	N/A	0.43	0.02 –2.43	No	Soil runoff
Turbidity (Lowest Monthly percent of samples meeting limit)	2020	TT	N/A	100	N/A	No	Soil runoff

**Tap water samples were collected for lead and copper analyses from sample sites throughout the community (Greenbrier service area)**

**City of Greenbrier Water Department**



## Consumer Confidence Report for 2020

Substance (Unit of Measure)	Year Sampled	AL	MCLG	Amount Detected (90 <sup>th</sup> % tile)	Sites Above AL/Total Sites	Violation	Typical Source
Copper (ppm)	2018	1.3	1.3	0.066	0/20	No	Corrosion of household plumbing systems; Erosion of natural deposits;
Lead (ppm)	2018	ND	0	ND	0/20	No	Corrosion of household plumbing systems; Erosion of natural deposits

### Unregulated Substances

#### City of Springfield Water Department

Substance (Unit of Measure)	Year Sample	Amount Detected	Range Low-High	Typical Source
Bromodichloro- methane (ppb)	2020	1.8	N/A-N/A	By-product of drinking water disinfection
Chlorodibromomethane (ppb)	2020	1.1	N/A_N/A	By-product of drinking water disinfection
Chloroform (ppb)	2020	2.2	N/A-N/A	By-product of drinking water disinfection
Sodium (ppm)	2020	2.2	N/A-N/A	By-product of drinking water disinfection
Chlorodibromo- methane (ppm)	2019	4.2	N/A-N/A	By-product of drinking water disinfection

<sup>1</sup> Footnote for City of Springfield Water & Wastewater Department: We are required to have a percent removal of 35%. We met the treatment technique for Total Carbon in 2019.

<sup>2</sup>Footnote for City of Springfield Water & Wastewater Department: Turbidity is a measure of the cloudiness of the water. It is monitored because it is a good indicator of the effectiveness of the filtration system.

#### **Total Coliform Bacteria Footnote for City of Greenbrier Water Department**

- During the past year, there have been numerous tests for over 80 contaminants that may be present in drinking water. In addition, there were 118 compliance samples tested in 2020 for coliform bacteria.

#### **Haloacetic Acids [HAA] Footnote for the City of Greenbrier Water Department**

- Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer. None of the test results were above the safe limit. The average test result was .0244.



## Consumer Confidence Report for 2020

### Total Trihalomethanes [TTHMs] Footnote for the City of Greenbrier Water Department

- During the past year, there were numerous tests for TTHM. None of the test results were above the safe limit. The average test result was .0369.

### Table Definitions

**PPM** (parts per million): One-part substance per million parts water (or milligrams per liter). **PPB** (parts per billion): One-part substance per billion parts water (or micrograms per liter).

**NTU** (Nephelometric Turbidity Units): Measurement of the clarity, or turbidity, of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

**AL** (Action Level): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**BDL** (Below Detection Limit): Indicates that the substance was not found by laboratory analysis.

**MCL** (Maximum Contaminant Level): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**MCLG** (Maximum Contaminant Level Goal): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**MRDLG** (Maximum Residual Disinfectant Level Goal): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**MRDL** (Maximum Residual Disinfectant Level): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**NA**: Not applicable

**ND**: (Not detected): Indicates that the substance was not found by laboratory analysis.

**TT** (Treatment Technique): A required process intended to reduce the level of a contaminant in drinking water.

**LRAA** (Locational Running Annual Average): The average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters. Amount Detected Values for TTHMs and HAAs are reported as LRAAs.

**SMCL** (Secondary Maximum Contaminant Level): These standards are developed to protect aesthetic qualities of drinking water and are not health based.

**90<sup>th</sup> %**: The level reported for lead and copper represent the 90<sup>th</sup> percentile of the total number of sites tested. The 90<sup>th</sup> percentile is equal to or greater than 90% of our lead and copper detections.